INTERSTATE ROCK PRODUCTS
General Building & Engineering Contractor

SIEVE ANALYSIS REPORT

Project:	Quality Control	**Date:**	8/19/2026
Sample Location:	Hurricane Cliffs PIt	**Tested By:**	PD
Aggregate Type:	1 Inch Decorative Rock	**Sample #**	1

Sieve Size	Weight Retained	% Retained	% Passing	BAND	Target
2"					
1.5"					
1"	173.21	12.0%	88		
3/4"	303.53	21.0%	67		
1/2"	645.59	44.7%	22.3		
3/8"	199.32	13.8%	8.5		
1/4"					
No. 4	17.65	1.2%	7.3		
No.8	3.42	0.2%	7.1		
No.10					
No.16					
No.30					
No.40					
No.50					
No.100					
No.200	58.63	4.1%	3		
TOTAL SAMPLE AGGREGATE WEIGHT:			1443.27		